

Data summary tables for Veolia Water Projects Ltd (VWP)

These tables contain a summary of results of monitoring undertaken by the water company in 2016 and submitted to the Drinking Water Inspectorate. The tables are published by the Inspectorate as part of the Chief Inspector's Report entitled *Drinking water 2016*.

The tables and full content of the Drinking Water Inspectorate's annual report are available on the Inspectorate's website at <http://www.dwi.defra.gov.uk>

Notes relating to the interpretation of the tables:

Columns on the following tables that are headed '1 percentile representing a minimum' and '99 percentile representing a maximum' contain figures for the 1 percentile and 99 percentile sample results respectively except where less than 100 samples were taken, when the figures are the actual maximum and minimum results.

The symbol < indicates that the result was less than the limit of detection of the analytical method used.

Published 13 July 2017
Drinking Water Inspectorate
Area 7e
9 Millbank
c/o Nobel House
17 Smith Square
London
SW1P 3JR

Enquiries: 0300 068 6400

Site Summary Data for Veolia Water Projects

Report Date Range: For the whole year 2016

Table VWP 1: Quality of water leaving service treatment works - European Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of works with failures
Nitrite (Works)	A013B	0.1 mg NO ₂ /l	16	0	< 0.008	< 0.008	0
Totals:			16	0			

Table VWP 2: Quality of water leaving service treatment works - National Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of works with failures
Coliform Bacteria	C001	0 number/100 ml	208	0	0	0	0
E coli	C002	0 number/100 ml	208	0	0	0	0
Totals:			416	0			

Table VWP 3: Quality of water leaving service treatment works - Additional Monitoring Requirements

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Colony Counts After 3 Days At 22°C (Indicator)	C007	No abnormal change	208	-n/a	0	2
Colony Counts After 48 Hours At 37°C (Indicator)	C013	No abnormal change	208	-n/a	0	4
Residual Disinfectant - Total	C010	No abnormal change	208	-n/a	0.4636	0.92
Turbidity (Indicator)	A002A	1 nephelometric turbidity units	207	0	< 0.1	0.3892
Totals:			831	0		

Table VWP 4: Quality of water leaving service reservoirs - National Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of reservoirs failing standard
Coliform Bacteria	C001	0 number/100 ml	264	1	0	0	0
E coli	C002	0 number/100 ml	264	0	0	0	0
Totals:			528	1			

Table VWP 5: Quality of water leaving service reservoirs - Additional Monitoring Requirements

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Colony Counts After 3 Days At 22°C (Indicator)	C007	No abnormal change	264	-n/a	0	17
Colony Counts After 48 Hours At 37°C (Indicator)	C013	No abnormal change	264	-n/a	0	23
Residual Disinfectant - Total	C010	No abnormal change	264	-n/a	0.16	0.79
Totals:			792	0		

Table VWP 9: Quality of water at consumer's tap (zones) - European Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of zones failing standard
1,2 Dichloroethane	F001	3 µg/l	8	0	< 0.04	< 0.04	0
Antimony	B008A	5 µg Sb/l	8	0	< 0.2	< 0.2	0
Arsenic	B001A	10 µg As/l	8	0	< 1	< 1	0
Benzene	F002	1 µg/l	8	0	< 0.02	< 0.02	0
Benzo (a) Pyrene	D007	0.01 µg/l	8	0	< 0.0005	< 0.0005	0
Boron	D005A	1 mg B/l	8	0	< 0.1	< 0.1	0
Bromate	F003	10 µg BrO3/l	8	0	< 0.5	< 0.5	0
Cadmium	B002	5 µg Cd/l	8	0	< 0.2	< 0.2	0
Chromium	B004	50 µg Cr/l	8	0	< 0.5	< 2	0
Copper	A024A	2 mg Cu/l	8	0	< 0.01	0.221	0
Cyanide	B003	50 µg CN/l	7	0	< 1	< 1	0
E coli	C002	0 number/100 ml	35	0	0	0	0
Enterococci	C003	0 number/100 ml	8	0	0	0	0
Fluoride	A027	1.5 mg F/l	8	0	0.046	0.125	0
Lead (>10 µg/l)	B007B	10 µg Pb/l	8	0	< 1	4.56	0
Mercury	B005	1 µg Hg/l	8	0	< 0.1	< 0.1	0
Nickel	B006A	20 µg Ni/l	8	0	< 2	< 2	0
Nitrate	A012	50 mg NO3/l	8	0	17.7	31.6	0
Nitrate/Nitrite Formula	A013C	1 mg NO2/l	8	0	< 0.354	< 0.632	0
Nitrite (Consumers tap)	A013A	0.5 mg NO2/l	8	0	< 0.008	< 0.008	0
Pesticides - Total Substances	B010	0.5 µg/l	8	0	0	0	0
Pesticides Atrazine	P004	0.1 µg/l	8	0	< 0.005	< 0.005	0
Polycyclic aromatic hydrocarbons	B011F	0.1 µg/l	8	0	0	0	0
Selenium	B009	10 µg Se/l	8	0	< 1	< 1	0
Tetrachloroethene/Trichloroethene - sum of two substances	D009B	10 µg/l	8	0	0	0.24	0
Total Trihalomethanes	D011	100 µg/l	8	0	3.42	10.92	0
Totals:			234	0			

Table VWP 10: Quality of water at consumer's tap (zones) - National Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of zones failing standard
Aluminium	A021	200 µg Al/l	8	0	< 5	5.32	0
Colour	A001	20 mg/l Pt/Co scale	24	0	< 1	1.2	0
Iron	A022	200 µg Fe/l	8	0	< 15	< 15	0
Manganese	A023	50 µg Mn/l	8	0	< 1	< 1	0
Organoleptic Odour	A003	0 Dilution number	12	0	0	0	0
Organoleptic Taste	A004	0 Dilution number	12	0	0	0	0
Sodium	A009	200 mg Na/l	8	0	6.45	11.1	0
Tetrachloromethane	D008	3 µg/l	8	0	< 0.06	< 0.06	0
Turbidity	A002	4 nephelometric turbidity units	34	0	< 0.1	1.3	0
Totals:			122	0			

Table VWP 11: Quality of water at consumer's tap (zones) - Additional Monitoring Requirements

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Ammonium (Indicator)	A014	0.5 mg NH4/l	12	0	< 0.04	< 0.04
Chloride (Indicator)	D002A	250 mg Cl/l	8	0	15	22
Clostridium Perfringens (Indicator)	C004A	0 number/100 ml	8	0	0	0
Coliform Bacteria (Indicator)	C001A	0 number/100 ml	35	0	0	0
Colony Counts After 3 Days At 22°C (Indicator)	C007	No abnormal change	33	-n/a	0	1
Colony Counts After 48 Hours At 37°C (Indicator)	C013	No abnormal change	33	-n/a	0	15
Conductivity (Indicator)	D001	2500 µS/cm	34	0	410	549
Hydrogen ion (pH)	A006	6.5 - 9.5 pH Value	34	0	7.2	7.7
Residual Disinfectant - Total	C010	No abnormal change	35	-n/a	0.19	0.82
Sulphate (Indicator)	A007	250 mg SO4/l	8	0	9	21
Total organic carbon (indicator)	A017	No abnormal change	8	-n/a	0.1	0.8
Totals:			248	0		