

Data summary tables for Albion Eco (ALE)

These tables contain a summary of results of monitoring undertaken by the water company in 2017 and submitted to the Drinking Water Inspectorate. The tables are published by the Inspectorate as part of the Chief Inspector's Report entitled *Drinking water 2017*.

The tables and full content of the Drinking Water Inspectorate's annual report are available on the Inspectorate's website at <http://www.dwi.defra.gov.uk>

Notes relating to the interpretation of the tables:

Columns on the following tables that are headed '1 percentile representing a minimum' and '99 percentile representing a maximum' contain figures for the 1 percentile and 99 percentile sample results respectively except where less than 100 samples were taken, when the figures are the actual maximum and minimum results.

The symbol < indicates that the result was less than the limit of detection of the analytical method used.

Published 11 July 2018
Drinking Water Inspectorate
Area 1A
Nobel House
17 Smith Square
London
SW1P 3JR

Enquiries: 0300 068 6400

Site Summary Data for Albion Eco Ltd

Report Date Range: For the whole year 2017

Table ALE 9: Quality of water at consumer's tap (zones) - European Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of zones failing standard
1 2-Dichloroethane (Total)	F001	3 µg/l	4	0	< 0.07	< 0.07	0
Antimony	B008A	5 µg Sb/l	4	0	0.071	0.12	0
Arsenic (Total)	B001A	10 µg As/l	4	0	0.19	0.34	0
Benzene (Total)	F002	1 µg/l	4	0	< 0.02	< 0.02	0
Benzo[a]Pyrene (Total)	D007	0.01 µg/l	4	0	< 0.00022	< 0.00022	0
Boron	D005A	1 mg B/l	4	0	0.00978	0.0152	0
Bromate	F003	10 µg BrO3/l	4	0	< 0.1	< 0.1	0
Cadmium (Total)	B002	5 µg Cd/l	4	0	0.008	0.011	0
Chromium (Total)	B004	50 µg Cr/l	4	0	0.27	0.36	0
Copper (Total)	A024A	2 mg Cu/l	4	0	0.0061	0.0382	0
Cyanide (Total)	B003	50 µg CN/l	4	0	< 0.7	0.8	0
E coli (faecal coliforms Confirmed)	C002	0 number/100 ml	12	0	0	0	0
Enterococci (Confirmed)	C003	0 number/100 ml	4	0	0	0	0
Fluoride (Total)	A027	1.5 mg F/l	4	0	0.02	0.02	0
Lead (10 - will apply 25.12.2013)	B007B	10 µg Pb/l	4	0	0.11	1.27	0
Mercury (Total)	B005	1 µg Hg/l	4	0	< 0.05	< 0.05	0
Nickel (Total)	B006A	20 µg Ni/l	4	0	0.73	1.58	0
Nitrate (Total)	A012	50 mg NO3/l	4	0	2.82	7.65	0
Nitrite - Consumer's Taps	A013A	0.5 mg NO2/l	4	0	< 0.002	< 0.002	0
Nitrite/Nitrate formula	A013C	1 mg NO2/l	4	0	< 0.37	< 0.37	0
Pesticides (Total by Calculation)	B010	0.5 µg/l	4	0	0.005	0.014	0
Pesticides 2,3,6-Tba	P074	0.1 µg/l	4	0	< 0.002	< 0.006	0
Pesticides Asulam	P133	0.1 µg/l	4	0	< 0.002	< 0.004	0
Pesticides Benazolin (Total)	P138	0.1 µg/l	4	0	< 0.003	< 0.005	0
Pesticides Clopyralid	P018	0.1 µg/l	4	0	< 0.003	0.008	0
Pesticides Diazinon	P024	0.1 µg/l	4	0	< 0.001	< 0.001	0
Pesticides Linuron	P051	0.1 µg/l	4	0	< 0.003	< 0.007	0
Pesticides MCPA 4-chloro-o-tolyloxyacetic acid	P054	0.1 µg/l	4	0	< 0.004	0.006	0
Pesticides MCPP (Mecoprop)	P053	0.1 µg/l	4	0	< 0.002	0.003	0
Polycyclic Aromatic Hydrocarbons (Total by Calculation)	B011F	0.1 µg/l	4	0	0	0	0
Selenium (Total)	B009	10 µg Se/l	4	0	0.37	0.81	0
Trichloroethene & Tetrachloroethene - Sum Of 2 Substances (Total by Calculation)	D009B	10 µg/l	4	0	0	0	0
Trihalomethanes (Total by Calculation)	D011	100 µg/l	4	0	34.41	53.79	0
Totals:			140	0			

Table ALE 10: Quality of water at consumer's tap (zones) - National Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of zones failing standard
Aluminium (Total)	A021	200 µg Al/l	4	0	7.43	15.1	0
Colour	A001	20 mg/l Pt/Co scale	4	0	< 0.5	1.7	0
Iron (Total)	A022	200 µg Fe/l	4	0	23.4	39.9	0
Manganese (Total)	A023	50 µg Mn/l	4	0	1.58	5.3	0
Odour	A003	0 Dilution number	4	0	0	0	0
Sodium (Total)	A009	200 mg Na/l	4	0	17.4	30.1	0
Taste (Taste Quant)	A004	0 Dilution number	4	0	0	0	0
Tetrachloromethane (Total)	D008	3 µg/l	4	0	< 0.02	< 0.02	0
Turbidity	A002	4 nephelometric turbidity units	4	0	0.13	0.42	0
Totals:			36	0			

Table ALE 11: Quality of water at consumer's tap (zones) - Additional Monitoring Requirements

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Ammonium (Total)	A014	0.5 mg NH ₄ /l	4	0	< 0.004	< 0.004
Chloride	D002A	250 mg Cl/l	4	0	17.7	32.1
Clostridium Perfringens	C004A	0 number/100 ml	4	0	0	0
Coliform Bacteria (Indicator)	C001A	0 number/100 ml	12	0	0	0
Colony Counts After 3 Days At 22°C (Colony Counts)	C007	No abnormal change	4	-n/a	0	0
Colony Counts After 48 Hours At 37°C (Colony Counts)	C013	No abnormal change	4	-n/a	0	0
Conductivity (Electrical Conductivity)	D001	2500 µS/cm	4	0	205	279
Hydrogen ion (pH) - Indicator (Hydrogen ion) (pH)	A006	6.5 - 9.5 pH Value	4	0	7.14	7.79
Residual Disinfectant - Total	C010	No abnormal change	12	-n/a	0.34	0.8
Sulphate	A007	250 mg SO ₄ /l	4	0	50	61.5
Total Organic Carbon	A017	No abnormal change	4	-n/a	1.1	1.5
Totals:			60	0		