



GUIDANCE ON THE IMPLEMENTATION OF THE WATER SUPPLY (WATER QUALITY) REGULATIONS 2016 (as amended) IN ENGLAND AND THE WATER SUPPLY (WATER QUALITY) REGULATIONS (WALES) 2018

The Regulations

Part 5 – Monitoring Additional Provisions

Regulation 15 [14]: Sampling: new sources

DOCUMENT CONTROL

The only controlled version of this document can be accessed on the DWI Website – <http://www.dwi.gov.uk/stakeholders/guidance-and-codes-of-practice/wswq/index.html>
Printed copies of this document, together with electronic copies held on local computers and other storage devices are uncontrolled.

PART 5 – MONITORING ADDITIONAL PROVISIONS

Regulation 15 [14] – Sampling: new sources

- 15.1 Regulation 15 [14] specifies the sampling requirements for
- (a) sources that have never previously been used for public water supply purposes and
 - (b) sources which have been previously been used for public supply purposes, but not for a period of 6 months or more.
- 15.1 Under the requirements of regulation 27, water suppliers must carry out a risk assessment for sources in both categories before using the source to supply drinking water. The risk assessment should inform the monitoring that should be undertaken under regulation 15 [14].
- 15.2 Any new abstraction point identified by a water supplier that is licensed for abstraction, represented by a sample point and intended for drinking water supply (as defined by regulation 17) is deemed to be a category (a) new source, and therefore subject to the sampling, risk assessment and reporting requirements in regulation 15 [14]. Sources used previously for private supply, or for non-domestic purposes, should also be treated as new sources for the purposes of regulation 15 [14].
- 15.3 Regulations 15(2) to (4) [14(2) to (4)] require that sources in category (a) must be sampled **before use** for all parameters in Schedules 1 and 2 of the Regulations, and any other element, organism or substance that could cause the water supply to be unwholesome, and to ensure that necessary treatment is in place to prevent unwholesome water being supplied.
- 15.4 Sources in category (b) must be sampled soon as reasonably practicable after the source has been put into supply, for conductivity, pH and turbidity and for any other parameter, organism, element or substance whose concentration may have deteriorated since the source was last used, causing a risk to wholesomeness.
- 15.5 Suppliers' risk assessment reports as required under regulation 28 should be submitted to the Inspectorate at least one month before the company plans to use a category (a) source. This is because regulation 15(5) [14(5)] prohibits the use of a new source for a period of one month following the date on which the Regulation 28 report was submitted to the Inspectorate.
- 15.6 Regulation 15(6) [14(6)] allows new sources to be used before the one month waiting period following submission of the risk assessment report has elapsed, provided that:
- i. the source is required for emergency use only, to prevent an unforeseen loss of supply, **and**
 - ii. a regulation 27 risk assessment has been completed (and therefore documented) **before** the source is put into supply.
- 15.7 Where any new source is introduced into an existing treated water bulk supply, it is the responsibility of the supplier to inform the recipient and to meet the requirements of regulation 15 [14]. The receiving company must ensure that the introduction of the new source is reflected within its own water safety planning methodology and regulation 27 risk assessment for the associated supply system.

- 15.8 Where any new source is introduced to an existing raw water bulk supply arrangement, the company intending to use the water for public water supply purposes must ensure that the requirements of regulation 15 [14] are met.
- 15.9 Regulation 15 [14] does not apply to new bulk supply arrangements (routine, emergency or otherwise) between existing wholesale suppliers, including inset appointees, when the source(s) has/have been used for public supply purposes within the last 6 months. In such cases the receiving company should carry out a full risk assessment as required by regulation 27, ideally before the supply is used, to ensure that consumers are protected from being supplied with unwholesome water. Supplying companies should make any necessary information available to receiving companies to allow the recipient to carry out a full risk assessment. [Information Letter 01/2014](#) reminds companies of their duty under section 68(1)(b) of the Water Industry Act 1991, to ensure no deterioration in the quality of water supplied to consumers. Suppliers should not, therefore, introduce any new bulk supplies, or extend any existing bulk supply arrangements, where there is a risk of unwholesomeness, even where a legal instrument is in place covering the relevant parameter(s).
- 15.10 Regulation 15(7) [14(7)] specifies that existing treatment works must be subject to a full regulation 27 risk assessment if a category (a) raw water source is introduced into the raw water supply to the works in order to maintain supplies during an emergency. The risk assessment must be carried out before the treated water is used to supply consumers.
- 15.11 If a supplier wishes to recommission an existing treatment works after any period, and it is not an emergency, then it is good practice to take and analyse samples for an appropriate suite of parameters and other substances, elements and organisms as determined by the risk assessment, to ensure that the supply is wholesome, before any water is supplied from the works. This is irrespective of the length of time that the treatment works has been out of use.
- 15.12 [Information Letter 06/12](#) includes the reporting formats to provide the necessary monitoring data and risk assessment information to the Inspectorate, including when seeking an exemption from the one month rule for new sources.

Revision notes:

Version	Revision	Date
1.0	First major version covering the 2016 Regulations	July 2016
1.1	Phrase encumbent company removed from para 15.9, replaced with the supplier. [3 month] rule added to para 15.14.	April 2017
2.0	Updated following publication of the 2018 amendment regulations in England and the 2018 Welsh Regulations.	September 2018
2.1		
2.2		
2.3		