

**ANNEX 3 to IL 9/2003**

**Authorised and automatic supply point authorisations**

**PARAMETERS FOR WHICH SUPPLY POINT AUTHORISATIONS ARE LIKELY  
TO BE GRANTED UNDER REGULATION 8(2)**

<b>Parameter</b>	<b>Comment</b>
Antimony Arsenic Cadmium Selenium	When the water company can demonstrate for a particular supply or supplies that these parameters have not been detected at significant concentrations in samples taken from consumers' taps for at least two years.
Trihalomethanes	When the water supply zones are supplied with water that originates solely from groundwater and the water company can demonstrate that the concentrations at consumers' taps have been an average of 30 µg/l or less for at least two years and not exceeded 50 µg/l in that time.